



PLAN

SECTION A - A

CONCRETE PIPE ANCHOR

NOT TO SCALE

NOTE:

1. USE ANCHORS WITH PIPE SLOPES GREATER THAN 20% AT SPACING SHOWN ON PLANS.
2. PERFORATED PVC DRAIN PIPE SHALL BE A MIN OF 12 FEET LONG AND BEDDED WITH WASHED ROCK, 6" MIN AROUND OUTSIDE DIAMETER OF PIPE.

APPROVED: SCOTT THOMASSON

REV. DATE: FEB. 1, 1997

WATER/WASTEWATER DIVISION



STANDARD DETAILS

CONCRETE PIPE ANCHOR

FILE WWDT850.DGN DRAWING NO. 850